

IEC**IECEE**

®

™

Ref. Certif. No.

CN74217

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Pushbutton

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the factory

Siemens Electrical Apparatus Ltd., Suzhou, Tiantai Branch
No.699-10, Jigong Road, Tiantai County, Zhejiang
Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix.

Trademark (if any)

APT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LA39;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020; IEC 60947-5-1:2024

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2025CQC-124914

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.04,2025

Signature:

谢肇煦

Xie ZhaoXu



LA39

Uimp:4kV;

Ui: 660V;

Ith: 10A;

Momentary action:

AC-15: Ue/Ie: 660V/0.8A, 380V/1.5A, 220V/2.5A, 110V/5A, 48V/10A, 24V/10A;

DC-13: Ue/Ie: 24V/3.6A, 48V/1.8A, 110V/0.8A, 220V/0.4A, 440V/0.2A;

Squirm action:

AC-15: Ue/Ie: 660V/2A, 380V/4A, 220V/6A, 110V/10A, 48V/10A, 24V/10A;

DC-13: Ue/Ie: 24V/6A, 48V/3A, 110V/1A, 220V/0.5A, 440V/0.25A;

Φ22

Type Ahead:exceptA3A4A5 selectorswitch,ZY(key release E-stop),ZL(pull to release E-stop), Y/YS(key buttons),TCY(push operation key switch) ,F,XF,CXF,XSF,CXSF:IP40; Other s(general pushbutton,D,T,TD,M,MT,MD,MTD,Z,A1A2 selector switch,Z9,ZC,MR,R,RD):IP54; Among them, Y and YS (key buttons) can be customized to IP54standard.TypeB head:

IP40(Generalbutton,D,T,TD,M,MT,MD,MTD,X,XS,CX,CXS,Zcan order IP65)

Page 1 of 1

Additional information (if necessary)

Date:

Nov.04,2025

Signature:

谢肇煦

Xie ZhaoXu