



Ref. Certif. No.

CN51159

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Flush Metal Pushbutton and Flush Metal Indicator

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the factory

Siemens Electrical Apparatus Ltd., Suzhou, Tiantai Branch
No.699-10, Jigong Road, Tiantai County, Zhejiang
Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

APT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FM19E, FM19N, FM19S, FM19L;

Additional information (if necessary may also be reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2020CQC-091848

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Aug.27,2020

Signature:

Lu Mei

CB 0057980

FM19E, FM19N, FM19S, FM19L;

Ui: FM19E, FM19N, FM19L:250V, FM19S:25V;

Uimp: FM19E, FM19N, FM19L:2.5kV, FM19S:0.5kV;

Ith: FM19E, FM19N:5A, FM19S:2A;

FM19E, FM19N:

AC-15:Ue/Ie:220V/0.5A,110V/1A, 24V/3A;

DC-13:Ue/Ie:220V/0.1A,110V/0.2A, 24V/0.7A;

FM19S:

DC-12:Ue/Ie:24V/0.3A;

Flush metal Pushbutton (head):

FM19E/N/S:IP65(Except FM19N keylock switch:IP54, selector:IP40),

Flush metal Indicator (head):FM19L:IP67;

Mounting hole diameter:Φ19mm

Page 1 of 1

Additional information (if necessary)

Date:

Aug.27,2020

Signature:



Lu Mei