

IEC**IECEE**

®

TM

Ref. Certif. No.

CN55184

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Pushbutton

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the factory

Siemens Electrical Apparatus Ltd., Suzhou, Tiantai Branch
No.699-10, Jigong Road, Tiantai County, Zhejiang
Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui:250V;Uimp:1.5kV;Ith:5A; AC-15:Ue/Ie:AC220V/0.5A,AC110V/1A,AC24V/2A;
DC-13:Ue/Ie:DC220V/0.1A,DC110V/0.2A,DC24V/0.7A; Φ16mm;IP65(Button
head).

Trademark / Brand (if any)

APT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LA39-G;

Additional information (if necessary may also be
reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found
to be in conformity withAs shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2021CQC-098664

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.10,2021

Signature:

谢肇旭

Xie ZhaoXu

**CB 0065352**