

IEC

IECEE



Ref. Certif. No.

CN54739-M3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Change-over Switch

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province,
P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province,
P.R.China

Name and address of the factory

Siemens Electrical Apparatus Ltd., Suzhou, Tiantai Branch
No.699-10 Jigong Road, Tiantai County, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui:690V;Uimp:4kV;lth:16A;AC-15:Ue/Ie: AC380V/1.8A;DC-13:Ue/Ie: DC220V/0.2A; The
LW39-16B head protection grade is IP40 (some model can be customized IP65); The LW39-16C
and The LW39-16Y head protection grade are all IP65

Trademark / Brand (if any)

APT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LW39-16B,LW39-16C,LW39-16Y;

Additional information (if necessary may also be
reported on page 2)The latest CB certificate No. is CN54739-M2, dated 2022-11-29. The
issuance of the M3 certificate is to increase functional code.A sample of the product was tested and found
to be in conformity withIEC 60947-5-1:2016(4th Edition);IEC 60947-1:2007;IEC
60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2021CQC-096647-M3

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jan.26,2024

Signature:

谢肇煦

Xie ZhaoXu



CB 0075126