

IEC**IECEE**

®

TM

Ref. Certif. No.

CN47733-A1/M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Indicator

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the factory

Siemens Electrical Apparatus Ltd., Suzhou, Tiantai Branch
No.699-10 Jigong Road, Tiantai, Zhejiang Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

APT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

AD16-22B, AD16-22BF, AD16-22C, AD16-22D, AD16-22E,
AD16-22F, AD16-22H, AD16-22I, AD16-22S, AD16-22M,
AD16-22SM, AD16-22W, AD16-22WF, AD16-22P,
AD16-22Q, AD16-22DY;

Additional information (if necessary may also be reported on page 2)

The latest CB No. is CN47733-A1/M1, dated 2021-09-15. The M2 certificate has been issued to optimize printed circuit board.

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2019CQC-085728-A1/M2

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.07,2023

Signature:

Xie ZhaoXu

CB 0074554

AD16-22B,AD16-22BF,AD16-22C,AD16-22D,AD16-22E,AD16-22F,AD16-22H,AD16-22I,
AD16-22S,AD16-22M,AD16-22SM,AD16-22W,AD16-22WF,AD16-22P,AD16-22Q,AD16-22DY;
Ui:500V;Uimp:4kV;
Ue:AC/DC:48V,63V,75V,110V,127V,150V,220V,270V,380V,400V,440V,500V;
AC:220V,230V,240V,250V,270V,380V;
Φ22mm;
IP65(The head of AD16-22B,AD16-22I,AD16-22D,AD16-22S and AD16-22DY);
IP54(The head of AD16-22C,AD16-22D,AD16-22S,AD16-22DY,AD16-22Q and AD16-22P);
IP40(The head of AD16-22E,AD16-22BF,AD16-22F,AD16-22H,AD16-22W and AD16-22WF);
IP30(The head of AD16-22M and AD16-22SM).

Page 1 of 1

Additional information (if necessary)

Date: Nov.07,2023

Signature:

谢肇煦

Xie ZhaoXu