

IEC**IECEE**

®

TM

Ref. Certif. No.

CN55185-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Pushbutton

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the factory

Siemens Electrical Apparatus Ltd., Suzhou, Tiantai Branch
No.699-10, Jigong Road, Tiantai County, Zhejiang
Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

APT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LA39

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN55185, dated 2021-11-22. The M1 certificate has been issued to change parameters.

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-097094-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.07,2023

Signature:

Xie ZhaoXu

CB 0074553

LA39

Ui:660V;Uimp:4kV;lth:10A;

Momentary action:AC-15:Ue/le:AC660V/0.8A,AC380V/1.5A,AC220V/2.5A,
AC110V/5A,AC48V/10A,AC24V/10A;

DC-13:Ue/le:DC24V/3.6A,DC48V/1.8A,DC110V/0.8A,
DC220V/0.4A,DC440V/0.2A;

Squirm action:AC-15:Ue/le:AC660V/2A,AC380V/4A,AC220V/6A,
AC110V/10A,AC48V/10A,AC24V/10A;

DC-13:Ue/le:DC24V/6A,DC48V/3A,DC110V/1A,DC220V/0.5A,
DC440V/0.25A;

Type A head:except A3,A4,A5 selector switch,ZY(key release E-stop),ZL(pull to release
E-stop),

Y/YS(key switch),TCY(push operation key switch) 、 F、 XF、 CXF、 XSF、 CXSF:IP40;

Other s(general pushbutton,D,T,TD,M,MT,MD,MTD,Z,A1A2 selector
switch,Z9,ZC,MR,R,RD):IP54;

Type B head: IP40(General button,D,T,TD,M,MT,MD,MTD,X,XS,CX,CXS,Z can order IP65);
Φ 22mm.

Page 1 of 1

Additional information (if necessary)

Date: Nov.07,2023

Signature:

谢肇旭

Xie ZhaoXu