



Ref. Certif. No.

CN50444

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Pushbutton

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province,
P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province,
P.R.China

Name and address of the factory

Siemens Electrical Apparatus Ltd., Suzhou, Tiantai Branch
No.699-10, Jigong Road, Tiantai, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

APT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

PB1;

Additional information (if necessary may also be reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found to be in conformity with

00901-CB2020CQC-091458

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn



Date: Jun.18,2020

Signature:

Lu Mei

CB 0057287

PB1;

Ui:600V;

Uimp:6kV;

Ith:10A;

AC-15:Ue/Ie:440V/4A,380V/4A,220V/6A,110V/6A;24V/6A,

DC-13:Ue/Ie:220V/0.4A,110V/1.2A,48V/4A,24V/6A,

AC-12:Ue/Ie:440V/10A,380V/10A,220V/10A,110V/10A,24V/10A;

DC-12:Ue/Ie:220V/1A,110V/3.5A,48V/8A,24V/10A;

Push button with indicator: Ue: AC/DC 6V, 12V, 15V, 24V, 30V, 36V, 48V, 110V, 127V,

AC220V,380V 50Hz, DC220V;

Φ22;

operating head: IP65,

switch element for screw connector and light emitting element for screw connector: IP20,

box of push button: IP65


Page 1 of 1

Additional information (if necessary)

Date:

Jun.18,2020

Signature:



Lu Mei