

IEC

IECEE



Ref. Certif. No.

CN70135

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Flush Metal Pushbutton and Flush Metal Indicator

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province,
P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province,
P.R.China

Name and address of the factory

Siemens Electrical Apparatus Ltd., Suzhou, Tiantai Branch
No.699-10 Jigong Road, Tiantai County, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui: FM12E/N/L: 250V; FM12S: 25V; Uimp: FM12E/N/L: 2.5kV;
FM12S: 0.5kV; Ith: FM12E:5A; FM12N: 3A; FM12S: 2A; FM12E:
AC-15:220V/0.5A, 110V/1A, 24V/2A;
DC-13:220V/0.1A, 110V/0.2A, 24V/0.7A; FM12N: AC-15: 220V/0.5A,
110V/1A, 24V/3A; DC-13: 220V/0.1A, 110V/0.2A,
24V/0.4A FM12S: DC-12: 24V/0.3A; Indicator
light: FM12L: AC/DC: 36V, 48V, 110V, 220V; Flush metal Pushbutton
(head): FM12E/N/S: IP65; Flush metal Indicator (head): FM12L: IP67
Mounting hole diameter: Φ 12mm

Trademark (if any)

APT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

FM12E, FM12N, FM12S, FM12L;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-1:2020; IEC 60947-5-1:2024

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2024CQC-118944

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.31,2024

Signature:

谢肇煦

Xie ZhaoXu

