

IEC

IECEE



TM

Ref. Certif. No.

CN67739

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

CAM Switch

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the factory

*Note: When more than one factory, please report on page 2*Siemens Electrical Apparatus Ltd., Suzhou, Tiantai Branch
No.699-10, Jigong Road, Tiantai County, Zhejiang
Province, P.R.China

Ratings and principal characteristics

Ui: 690V; Uimp: 6kV; Ith: 25A; AC-15: Ue/Ie: 380V/8A,
220V/12A; DC-13: Ue/Ie: 110V/2.5A, 220V/1.25A; AC-21,
AC-22: Ue/Ie: 380V/25A; AC-3: Ue/Ie: 380V/12A; AC-4:
Ue/Ie: 380V/10A; IP40 (LW39-25 series, LW39-25P series
can be customized with IP65)

Trademark (if any)

APT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LW39-25;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-5-1:2016(4th Edition); IEC 60947-1:2007; IEC
60947-1:2007/AMD1:2010; IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2024CQC-116138

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.25,2024

Signature:

谢肇煦

Xie ZhaoXu

