

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Pushbutton

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou  
No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province,  
P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou  
No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province,  
P.R.China

Name and address of the factory

Siemens Electrical Apparatus Ltd., Suzhou, Tiantai Branch  
No.699-10 Jigong Road, Tiantai County, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp: 6kV; Ui: 600V; Ith: 10A; AC-15: Ue/Ie: 440/4A, 380V/4A,  
220V/6A, 110V/6A, 24V/6A, AC-12: Ue/Ie: 440V/10A, 380V/10A,  
220V/10A, 110V/10A, 24V/10A, DC-13: Ue/Ie: 220V/0.4A,  
110V/1.2A, 48V/4A, 24V/6A, DC-12: Ue/Ie: 220V/1A, 110V/3.5A,  
48V/8A, 24V/10A  $\Phi$ 22mm; Pushbutton actuator: IP65, Contact block  
and illuminated module: IP20

Trademark (if any)

APT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

PB3

Additional information (if necessary may also be  
reported on page 2)A sample of the product was tested and found  
to be in conformity withIEC 60947-5-1:2016(4th Edition); IEC 60947-1:2007, IEC  
60947-1:2007/AMD1:2010, IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which  
forms part of this Certificate

00901-CB2025CQC-123219

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jul.30,2025

Signature:

谢肇煦

Xie ZhaoXu

